



# Certificate of Conformity

Product Certification Scheme 5

**Certificate No. 30940-01-22-INT**

This certificate applies to the product

**Supervised Premises Transceiver (SPT)**

with name and/or type designation

**DualCom Pro 2**

Placed on the market by

**CSL DualCom Ltd.**

Building 4, Croxley Park, Hatters Lane, Watford, WD18 8YF

Produced in the manufacturing plants by

**Tenstep Ltd.**

Unit 14, Oldbury Business Centre, Oldbury Rd,  
Cwmbran, NP44 3JU

**SRXGlobal (M) SDN. BHD**

Tingkat 4, 12B Jalan Bayu, Kawasan Perindustrian  
Hasil, 81200 Johor Bahru Johor

This certificate attests that all provisions concerning the assessment and the performance described in the standards

**EN 50131-10:2014**

**EN 50136-2:2013**

**EN 50136-1:2012/A1:2018**

are applied and that the product fulfils all the prescribed requirements

This Certificate is valid until 2026-03-18

Høvik, Norway 2022-03-18

For Applica Test & Certification AS

A handwritten signature in blue ink that reads 'Jan Rune Pedersen'.

Jan Rune Pedersen,  
Certification Manager



*Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.*

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. [www.applica.no](http://www.applica.no)

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2022-03-18

Products covered by this certificate		
Product Name	Product Configuration	Applied Standards
DualCom Pro 2	DigiAir Pro 2 - LAN	EN 50131-10:2014
	DigiAir Pro 2 - Radio	EN 50136-1:2012/A1:2018
	GradeShift Pro 2– Radio/Radio	EN 50136-2:2013
	GradeShift – Pro 2 - LAN/Radio	EN 50130-4:2011/A1:2014 EN 50130-5:2011

Products Specifications				
Product Name	Security Grade	Security Grade	ATS configuration EN 50136- 1:2012/A1:2018	SPT Structure EN 50131-10:2014
DualCom Pro 2	DigiAir Pro 2 - LAN	Grade 1-4 *	SP 5	Type Y
	DigiAir Pro 2 - Radio	Grade 1-4 *	SP 5	
	GradeShift Pro 2– Radio/Radio	Grade 1-4*	DP 4	
	GradeShift – Pro 2 - LAN/Radio	Grade 1-4 *	DP 4	

### Application/Limitation

- Environmental Class 2
- Max. SP 4 when Dial Capture
- To be used in accordance with the supplier's installation and operation instructions
- The products are intended to be installed inside an enclosure of another intrusion alarm component. For the purposes of conforming to EN 50131-10:2014 and EN 50136-2:2013 the enclosure shall be that of a CIE conforming to EN 50131-3:2009. The power supply equipment used shall conform to EN 50131-6:2017.

Documents Reviewed	
Document ID	Description
Technical Report 30799	EN 50131-10:2014 EN 50136-1:2012/A1:2018 EN 50136-2:2013 EN 50130-4:2011/A1:2014 EN 50130-5:2011
30943_FPC_03_Report from Inspection	FPC report Tenstep
30956 FPC_03_Report from Inspection	FPC report SRX Global

**Notice:** The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

### Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plans
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE