

Certificate of Constancy of Performance

Certificate No. 2544-CPR-30940-F01-22 Rev.2

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (CPR)

This certificate applies to the construction product

Alarm transmission and fault warning routing equipment

with name and/or type designations

DualCom Pro 2 and DualCom Pro 3

Placed on the market by

CSL DualCom Ltd.

Building 4, Croxley Park, Hatters Lane, Watford, WD18 8YF

Produced in the manufacturing plants by

Tenstep Ltd.

Unit 14, Oldbury Business Centre, Oldbury Rd,
Cwmbran, NP44 3JU

SRXGlobal (M) SDN. BHD

Tingkat 4, 12B Jalan Bayu, Kawasan Perindustrian
Hasil, 81200 Johor Bahru Johor


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 54-21:2006

under System 1 are applied and that the product fulfils all the prescribed requirements set out above.

This Certificate is valid until 2026-03-18

Høvik, Norway 2023-07-12
for Applica Test & Certification AS



Jan Rune Pedersen,
Certification Manager



Notified Body (NB) 2544

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2022-03-18
1	Added “System 1” to the first page.	2022-10-20
2	Adding DualCom Pro 3	2023-07-12

Products covered by this certificate comply with EN 54-21:2006		
Product Name	Product Configuration	Type of transmission system in accordance with EN 54-21:2006
DualCom Pro 2	DigiAir Pro 2 - Radio	Type 1
	GradeShift Pro 2 – Radio/Radio	
	GradeShift Pro 2 – LAN/Radio	
DualCom Pro 3	DigiAir Pro 3 - Radio	
	DigiAir Pro 3 - LAN	

- **Application/Limitation**

- To be used in accordance with the supplier’s installation instructions
- Suitable for indoor application
- Shall be installed in a housing that is compliant with the requirements of EN 54-21:2006
- The power supply equipment used shall comply with EN 54-4:1997+A1:2002+A2:2006

Documents Reviewed	
Document ID	Description
Technical Report 31168	EN 54-21:2006
Technical Report 30799	EN 54-21:2006
30943_FPC_03_Report from Inspection	FPC report Tenstep
30956 FPC_03_Report from Inspection	FPC report SRX Global

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of the product and/or production process may render this certificate invalid.

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The Certificate remains valid based upon satisfactory annual factory production control audits

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Changes in the test methods and/or factory production control requirements included in the harmonised standards, used to assess the performance of the declared characteristics
- Significant changes in the manufacturing plants

END OF CERTIFICATE