



Certificate of Conformity

Product Certification Scheme 5

Certificate No. 30940-01-22-INT Rev.1

This certificate applies to the product

Supervised Premises Transceiver (SPT)

with name and/or type designation

DualCom Pro 2 and DualCom Pro 3

Placed on the market by

CSL DualCom Ltd.

Building 4, Croxley Park, Hatters Lane, Watford, WD18 8YF

Produced in the manufacturing plants by

Tenstep Ltd.

Unit 14, Oldbury Business Centre, Oldbury Rd,
Cwmbran, NP44 3JU

SRXGlobal (M) SDN. BHD

Tingkat 4, 12B Jalan Bayu, Kawasan Perindustrian
Hasil, 81200 Johor Bahru Johor

This certificate attests that all provisions concerning the assessment and the performance described in the standards

EN 50131-10:2014

EN 50136-2:2013

EN 50136-1:2012/A1:2018

are applied and that the product fulfils all the prescribed requirements

This Certificate is valid until 2026-03-18

Høvik, Norway 2023-07-11

For Applica Test & Certification AS

A handwritten signature in blue ink, appearing to read 'Jan Rune Pedersen'.

Jan Rune Pedersen,
Certification Manager



Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2022-03-18
1	Adding DualCom Pro 3	2023-07-11

Products covered by this certificate		
Product Name	Product Configuration	Applied Standards
DualCom Pro 2	DigiAir Pro 2 - LAN	EN 50131-10:2014
	DigiAir Pro 2 - Radio	EN 50136-1:2012/A1:2018
	GradeShift Pro 2– Radio/Radio	EN 50136-2:2013
	GradeShift – Pro 2 - LAN/Radio	EN 50130-4:2011/A1:2014 EN 50130-5:2011
DualCom Pro 3	DigiAir Pro 3 - LAN	EN 50131-10:2014 EN 50136-1:2012/A1:2018 EN 50136-2:2013
DualCom Pro 3	DigiAir Pro 3 – Radio	EN 50130-4:2011/A1:2014 EN 50130-5:2011

Products Specifications				
Product Name	Security Grade	Security Grade	ATS category EN 50136- 1:2012/A1:2018	SPT Structure EN 50131-10:2014
DualCom Pro 2	DigiAir Pro 2 - LAN	Grade 1-4 *	SP 5	Type Y
	DigiAir Pro 2 - Radio	Grade 1-4 *	SP 5	
	GradeShift Pro 2– Radio/Radio	Grade 1-4*	DP 4	
	GradeShift – Pro 2 - LAN/Radio	Grade 1-4 *	DP 4	
DualCom Pro 3	DigiAir Pro 3 - LAN	Grade 1-4 *	SP 5	Type Y
	DigiAir Pro 3 - Radio	Grade 1-4 *	SP 5	

Application/Limitation

- Environmental Class 2
- Max. SP 4 when Dial Capture
- To be used in accordance with the supplier's installation and operation instructions
- The products are intended to be installed inside an enclosure of another intrusion alarm component. For the purposes of conforming to EN 50131-10:2014 and EN 50136-2:2013 the enclosure shall be that of a CIE conforming to EN 50131-3:2009. The power supply equipment used shall conform to EN 50131-6:2017.

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Documents Reviewed	
Document ID	Description
Technical Report 31168	EN 50131-10:2014 EN 50136-1:2012/A1:2018 EN 50136-2:2013 EN 50130-4:2011/A1:2014 EN 50130-5:2011
Technical Report 30799	EN 50131-10:2014 EN 50136-1:2012/A1:2018 EN 50136-2:2013 EN 50130-4:2011/A1:2014 EN 50130-5:2011
30943_FPC_03_Report from Inspection	FPC report Tenstep
30956 FPC_03_Report from Inspection	FPC report SRX Global

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plans
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE